



LEGEND:

BLDG CONDENSATE (BLDG-SUPPLIED)	-----
BLDG HOT WATER (BLDG-SUPPLIED)	-----
BLDG STEAM (BLDG-SUPPLIED)	-----
DES CONDENSATE (DES-SUPPLIED)	-----
DES STEAM (DES-SUPPLIED)	-----
EQUIPMENT (BLDG-SUPPLIED)	-----
INSTRUMENTATION (DES-SUPPLIED)	-----

NOTES:

- ADDITIONAL INSTRUMENTATION, CONTROLS AND EQUIPMENT MAY BE REQUIRED ON THE CUSTOMER PIPING AND SYSTEM, PER THE CUSTOMER REQUIREMENTS, THAT ARE NOT SHOWN ON THIS SCHEMATIC.
- DEVICES NOTED AS "OPTIONAL" MAY BE REQUIRED DEPENDING ON THE BUILDING LOAD, SPACE AVAILABILITY OR TECHNICAL REQUIREMENT.
- IF SUMMER METER IS NOT REQUIRED BASED ON LOAD, FCV-300 IS NOT REQUIRED.
- THE CUSTOMER PIPING AND EQUIPMENT SHOWN REPRESENTS THE GENERAL REQUIREMENTS. THE CUSTOMER IS RESPONSIBLE FOR THE DESIGN AND ENGINEERING OF THEIR PIPING AND EQUIPMENT.
- ADDITIONAL DRIP LEGS AND TRAP LINES MAY BE REQUIRED.
- DES INSTRUMENTS SHALL BE INSTALLED SUCH THAT THEY REMAIN ACCESSIBLE ON ALL SIDES WITH ADEQUATE CLEARANCES FOR ANNUAL CALIBRATION AND VERIFICATION BY DES PERSONNEL.

PRELIMINARY - NOT FOR CONSTRUCTION

PLOT DATE : 10/06/2021

PRELIMINARY - NOT FOR CONSTRUCTION

METRO NASHVILLE
DISTRICT ENERGY SYSTEM

TYPICAL STEAM
CUSTOMER CONNECTION

Metro Nashville
DISTRICT ENERGY SYSTEM



DES PROJECT NO. 863

REVISIONS

NO.	DATE	DESCRIPTION

DRAWN BY: KLJ	APP'D. BY:	CHECKED:
------------------	------------	----------

DATE: 10/06/21	DATE:	DATE:
-------------------	-------	-------

PROJECT NO.
863

DRAWING NO.
SK-02